

July 2012

Dear Pleasant Valley Water Member

We are pleased to furnish you with the following information about the water quality and services we provide to our members.

Pleasant Valley Water Company purchases our water from the City of Tillamook as a finished product. The City does all of the filtration and treatment. Pleasant Valley Water collects monthly samples for coliform bacteria levels, yearly samples for Disinfection By-Products and Lead & Copper samples every 3 years. Enclosed is the 2011 Annual Water Quality Report from the Tillamook Water Department containing contaminant test results and other important information regarding your drinking water.

Water delivery to our Company enters the system from one tap point on the City's mainline at Clemens Corner Road and is pumped through our system by two alternating pumps at the Clemens Corner Pump Station. The system is backed up by an 185,000 gallon reservoir on Fawcett Creek Road, which gravity feeds back into the system.

The Oregon Drinking Water Program has identified criteria for determining whether a community public water system should be considered to have outstanding performance. This designation is given at the completion of a water system survey. A water system survey is an on-site review of a system's sources, treatment, storage facilities, distribution system, operation and maintenance procedures, monitoring and management, for the purpose of evaluating the system's capability of providing safe water to the public. Systems that are designated outstanding performers will have their water system survey frequency reduced from every 3 years to every 5 years. Pleasant Valley Water Company is pleased to inform you that we have been designated an outstanding performer with our December 2011 system survey!

We invite you to attend our quarterly board meetings, held the last Wed. of the first month of each quarter, in the Carl Rawe Meeting Room at Tillamook PUD, 1115 Pacific Ave. in Tillamook. Meetings are at 7:00 pm.

Your 2011/2012 Board Members Are:

Dave Joyce, President	842-3350	Steve Rouse, Board Member	842-6494
Todd Johnson, V President	815-8306	John Putman, Board Member	842-7109
Terry Jones, Sec/Treas	842-5508	Leroy Satter, Board Member	842-5607
Bill Porter, Board Member	842-8039	Mark Hopkins, Board Member	842-5215
Amy Braden, Bookkeeper	842-8352	Ken/Nonda Zwald, Operators	842-1515

Sincerely,

Pleasant Valley Water Company
Board of Directors

TEST RESULTS						
Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants						
Copper 90 th percentile Aug 2010	N	.000	ppm (parts per million)	1.3	Action Level 1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead 90 th percentile Aug 2010	N	.000	ppb (parts Per billion)	0	Action Level 15	Corrosion of household plumbing systems, erosion of natural deposits
Nitrate March 2009	N	1.8	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Total Coliform	N	None	n/a			