

Dear Pleasant Valley Water Company Member

We are pleased to furnish you with the following information about the water quality and services we provide to our members.

Pleasant Valley Water Company purchases our water from the City of Tillamook as a finished product. The City does all the filtration and treatment. PVWC collects monthly samples for Coliform Bacteria levels, yearly samples for Disinfection By-Products and Lead & Copper samples every 3 years. Enclosed is the 2022 Annual Water Quality Report from the Tillamook Water Department containing contaminant test results and other important information regarding your drinking water.

Water delivery to our Company enters the system from one tap point on the City's mainline at Clemens Corner Road and is pumped into our system by two alternating pumps at the Clemens Corner Pump Station. The system is backed up by a 185,000 gallon reservoir on Fawcett Creek Road, which gravity feeds back into the system.

Oregon Drinking Water Services has identified criteria for determining whether a community public water system should be considered to have outstanding performance. This designation is given at the completion of a water system survey (formerly referred to as a sanitary survey). A water system survey is an on-site review of a system's sources, treatment, storage facilities, distribution system, operation and maintenance procedures, monitoring, and management, for the purpose of evaluating the system's capability of providing safe water to the public. Systems that are designated outstanding performers will have their water system survey frequency reduced from every 3 years to every 5 years. We are happy to inform you that your PVWC water system has been named an Outstanding Performer with the completion of our last survey in 2021.

Our Lead & Copper samples are on a three-year cycle and were done in 2022. There were no significant amounts of Lead or Copper in the 10 samples tested. These will be due again in 2025.

We invite you to attend our quarterly board meetings, held the fourth Wed. of the first month of each quarter. Please call Amy at 503-812-1660 for location and time of this meeting.

Your Board Members Are:

Todd Johnson, President	815-8306	Bill Porter, Board Member	842-8039
Terry Jones, Sec/Treas	842-5508	Karl Zweifel, Board Member	842-5016
Leroy Satter, Board Member	842-5607	Ken Williams, Board Member	815-1735
Amy Braden, Bookkeeper	812-1660	Zwald Water Utility Services Operator	842-1515

Sincerely,

Pleasant Valley Water Company
Board of Directors

**Pleasant Valley Water Company
TEST RESULTS**

Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants						
Copper Aug 2022	N	0.000	ppm (parts per million)	1.3	Action Level 1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead Aug 2022	N	.0020	ppb (parts per billion)	ND	Action Level 15	Corrosion of household plumbing systems, erosion of natural deposits
Nitrate Year 2021 Killam/Fawcett Well 2 Well3	N N N N	 .1.03 .0.876 3.23	ppm	10 10 10 10	10 10 10 10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Disinfection Byproducts						
Trihalomethanes (TTHM) Aug 2021		.0176000	ppm		.080	Disinfection Byproducts, Byproduct Precursors, Disinfection Residuals
Haloacetic Acids (HAA5) Aug 2021		.0038000	ppm		.060	Disinfection Byproducts, Byproduct Precursors, Disinfection Residuals
Microbiological Contaminants						
Total Coliform Bacteria	N	None detected	present/ not present	0	0	Breaks in pipe, pipeline replacement construction
Fecal Coliform	N	in 2022		0	0	