

June 2017

Dear West Hills Water Company Member

We are pleased to furnish you with the following information about the water quality and services we provide to our members.

West Hills Water Company purchases our water from the City of Tillamook as a finished product. The City does all of the filtration and treatment. WHWC collects monthly samples for Coliform Bacteria levels, yearly samples for Disinfection By-Products and Lead & Copper samples every 3 years. Enclosed is the 2016 Annual Water Quality Report from the Tillamook Water Department containing contaminant test results and other important information regarding your drinking water.

A water system survey is an on-site review of a system's sources, treatment, storage facilities, distribution system, operation and maintenance procedures, monitoring, and management, for the purpose of evaluating the system's capability of providing safe water to the public. Our last survey was completed in September of 2015, so we will be due again in September of 2018.

Our Lead & Copper samples are on a three year cycle and were done in 2016. There were no significant amounts of Lead or Copper in the 10 samples tested. These will be due again in 2019.

TEST RESULTS						
Contaminant	Violati on Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants						
Copper Sept 2016	N	0.1340	ppm (parts per million)	1.3	Action Level 1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead Aug 2016	N	.000	ppb (parts per billion)	ND	Action Level 15	Corrosion of household plumbing systems, erosion of natural deposits
Nitrate Year 2015	N N N N	.	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Total Coliform	N	ND	present/ not present	0	0	Breaks in pipe, pipeline replacement construction